



Ref. Certif. No.

CN36635

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE

Product
Produit

Moulded Case Circuit-breakers

Name and address of the applicant
Nom et adresse du demandeur

Zhejiang Tengen Electrics Co.,Ltd.
TENGEN Industry Zone, Liushi, Yueqing, Zhejiang Province,
P.R.China

Name and address of the manufacturer
Nom et adresse du fabricant

Zhejiang Tengen Electrics Co.,Ltd.
TENGEN Industry Zone, Liushi, Yueqing, Zhejiang Province,
P.R.China

Name and address of the factory
Nome et adresse de l'usine

Zhejiang Tengen Electrics Co.,Ltd.
TENGEN Industry Zone, Liushi, Yueqing, Zhejiang Province,
P.R.China

Note: When more than one factory, please report on page 2
Note: Lorsque plus d'une usine, veuillez utiliser la 2^{ème} page

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

TENGEN

Model / Type Ref.
Ref. De type

TGM1-250

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page)

PUBLICATION

EDITION

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

IEC 60947-2:2006(4th Edition)

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

00901-CB2015CQC-066214

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification



CHINA QUALITY CERTIFICATION CENTRE

Date: 2016-03-22

Signature: Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
www.cqc.com.cn

CB 0033993



Ref. Certif. No.

CN36635

TGM1-250

Uimp:8kV;

Ui:800V

Ue: AC415V, AC690V;

In: 100A, 125A, 160A, 180A, 200A, 225A, 250A;

Over-current release: thermo-magnetic;

Type L: AC415V Ics=22kA Icu=35kA; AC690V Ics=4kA Icu=5kA;

Type M: AC415V Ics=35kA Icu=50kA; AC690V Ics=5kA Icu=10kA;

Selectivity category: A;

Suitability for insulation;

2P(AC415V); 3P, 4P(AC415/690V)

Auxiliary contact(1NO+1NC, 2NO+2NC, 4NO+4NC):

Ith: 3A

AC-15: AC415/0,3A; DC-13: DC220V/0,15A

Accessories with electronic circuits:

Motor operator: CDM3-225/M, Us: AC240V, AC415V

Shunt release: 225FT, Us: AC240V

Undervoltage release: 225QT, Us: AC240V, AC415V

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2016-03-22

Signature:

Wang Kejiao